

Troubleshooting for other components


IV Cause and Action for alarm/trip relating to Software & operating procedure

c. LOCAL / REMOTE GP RESPONSE TIME OUT

Alarm indicates that the GP(Graphic Panel) does not work.

Cause	Description	Action	Cause	Description	Action
1	Power Failure	1	2	HUB Port Failure	1

Action 1



Verify the GP monitor (Local & Remote) are turned on

Action 2



Check the connection status of the HUB Port and LAN cables